

UNIVERSITY OF NORTH BENGAL

Accredited by NAAC with Grade A

Superintendent (Acting)
University Press



ENLIGHTENMENT TO PERFECTION

(0353) 2776384 (Office)
P.O. NORTH BENGAL UNIVERSITY
Raja Rammohunpur, Dt. Darjeeling,
West Bengal, India, Pin-734013

Ref. No. UPP/191/17-18/CN

Dated. 08/02/18

QUOTATION NOTICE

The Superintendent (Acting), University Press, University of North Bengal invites sealed quotation from the vendors for 1.5 ton capacity Window/Split Air Conditioner (Five star rated) against Buy-Back of 1.5 ton capacity Window Air Conditioner (Accent make of year 2001).


Specifications for supply, installation, testing and commissioning of eco friendly Inverter type wall mounted split air conditioner

Cooling capacity	1.5 Ton
Air circulation (Cu Ft / hr)	Greater than 550
Noise Level (dB) indoor unit (cooling unit)	Less than 30 db at (minimum speed)
Average electrical power	1.6 KW with tolerance of 10%
Warranty period	One year on complete unit and after completion of one year four years on compressor

The interested vendors shall submit the rate/quotation inclusive of all taxes/GST/Charges to the Superintendent (Acting), University Press, Raja Rammohunpur, P.O. North Bengal University, Dt. Darjeeling, Pin - 734013 within 2:00 P.M. of 20/02/18.

Terms and conditions

- 1) Eco friendly gas R410a or equivalent should be used as a refrigerant. The refrigerant gas should not have any action in Ozone layer depletion. The eco friendly Inverter type wall mounted split air conditioner should be energy efficient. Department will not be provided any wire or cable for the installation of same. The out door and indoor units power supply cable should be provided with single length cable, as no joints are permitted. Only Copper material condenser units and cooling unit will be accepted.
- 2) Minimum 4.00 mtrs Copper tubes along with each unit must be supplied. In order to cover the blank area, as per site requirement supplier should provide glasses (5mm) and sun films, MS grills or Aluminum grills in place of old air conditioners. Parties should have to complete all finishing works like pocket filling, wall colour works or any other civil works from inside and out side of building before submission of final bill.
- 3) No water leakage should occur after repair works completed by the supplier, at least for one rainy season. Only branded make units will be accepted.
- 4) The Vendor(s) shall provide the self-attested copies of PAN, GST.
- 5) The rate shall be inclusive of all taxes (GST). The vendor should clearly mention the Base Price, GST Percentage of the article, GST Value and Total Price. Without proper Break-up of rate, quotation shall not be considered. Quotation should be valid for at least three months.
- 6) The University authority reserves the right to accept or reject any/all quotation(s) without assigning any reason and shall not be bound to accept the lowest quotation.


8/2/18
Assistant Superintendent
University Press
University of North Bengal
P.O. NBU Dist. Darjeeling
West Bengal, Pin-734013


09.02.2018
Dr. Minakshi Chakraborty
Superintendent (Acting)
UNIVERSITY PRESS
University Of North Bengal
N.B.U. Dist. Darjeeling
West Bengal 734013